

**Annual Drinking Water Quality Report
City of Sunrise Beach Village, TX
PWS#: TX1500010**



Annual Water Quality Report for the Period of January 1 to 31 December 2015
This report is intended to provide you with the important information about your drinking water and the efforts made by the water system to provide safe drinking water.

The source of water for CITY OF SUNRISE BEACH VILLAGE is Ground Water from the Alluvium and Pre-Cambian Granit Aquifer.

For more information regarding this report contact:
Tim McClain
Phone: 325-248-3596

Este reporte incluye informacion importante sobre el agua para tomar. Para asistencia en espanol, Favor de llamar al telefonao (325) 248-3596

1. The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pickup substances resulting from the presence of animals or from human activity.
2. Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the EPAs Safe Drinking Water Hotline at (800) 426-4791. Contaminants that may be present in source water include:
 - Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
 - Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
 - Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban storm water runoff, and residential uses.
 - Organic chemical contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.
 - Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
3. In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water which must provide the same protection for public health.
4. Contaminants may be found in drinking water that may cause taste, color, or odor problems. These types of problems are not necessarily causes for health concerns. For more information on taste, odor, or color of drinking water, please contact the system's business office.
5. You may be more vulnerable than the general population to certain microbial contaminants, such as Cryptosporidium, in drinking water. Infants, some elderly, or immunocompromised persons such as those undergoing chemotherapy for cancer; persons who have undergone organ transplants; those who are undergoing treatment with steroids; and people with HIV/AIDS or other immune system disorders, can be particularly at risk from infections. You should seek advice about drinking water from your physician or health care providers. Additional guidelines on appropriate means to lessen the risk of infection by Cryptosporidium are available from the Safe Drinking Water Hotline (800-426-4791).
6. If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. We are responsible for providing high quality drinking water, but we cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Lead and Copper

Definitions:

Action Level Goal (ALG): The level of a contaminant in drinking water below which there is no known or expected risk to health. ALGs allow for a margin of safety.

Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Lead and Copper	Date Sampled	MCLG	Action Level (AL)	90th Percentile	# Sites Over AL	Units	Violation	Likely Source of Contamination
Copper	09/08/2014	1.3	1.3	0.33	0	ppm	No	Erosion of natural deposits; Leaching from wood preservatives; Corrosion of household plumbing systems.
Lead	09/08/2014	0	15	4.8	0	ppb	No	Corrosion of household plumbing systems; Erosion of natural deposits.

Regulated Contaminants

Disinfectants and Disinfection By-Products	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Haloacetic Acids (HAA5)*	2015	4	3.5 - 4.3	No goal for the total	60	ppb	No	By-product of drinking water disinfection.
Total Trihalomethanes (TTHM)	2015	5	4.9-4.9	No goal for the total	80	Ppb	No	By-product of drinking water disinfection

Inorganic Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Barium	05/13/2010	0.14	0.14 - 0.14	2	2	ppm	No	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits.
Fluoride	08/19/2014	0.4	0.4 - 0.4	4	4.0	ppm	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories.
Nitrate [measured as Nitrogen]	2015	1	0.92 - 0.92	10	10	ppm	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits.

Radioactive Contaminants	Collection Date	Highest Level Detected	Range of Levels Detected	MCLG	MCL	Units	Violation	Likely Source of Contamination
Combined Radium 226/228	09/26/2013	4	4 - 4	0	5	pCi/L	No	Erosion of natural deposits.
Gross alpha excluding radon and uranium	09/26/2013	3	2 - 3	0	15	pCi/L	No	Erosion of natural deposits.
Uranium	09/26/2013	1.9	1.9 - 1.9	0	30	ug/l	No	Erosion of natural deposits.

Maximum Residual Disinfectant Level

Disinfectants	Collection Date	Average Level	Minimum Level	Maximum Level	MRDL	MRDLG	Units	Violation	Likely Source of Contamination
Chlorine Residual C12	2015	2.28	1.00	2.74	4.0	4.00	ppm	No	Water additive used to control microbes

Water Quality Test Results

Definitions:

Avg:	Regulatory compliance with some MCLs are based on running annual average of monthly samples.
Maximum Contaminant Level or MCL:	The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
Maximum Contaminant Level Goal or MCLG:	The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
Maximum residual disinfectant level or MRDL:	The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
Maximum residual disinfectant level goal or MRDLG:	The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MFL	million fibers per liter (a measure of asbestos)
na:	not applicable.
NTU	nephelometric turbidity units (a measure of turbidity)
pCi/L	picocuries per liter (a measure of radioactivity)
ppb:	micrograms per liter or parts per billion - or one ounce in 7,350,000 gallons of water.
ppm:	milligrams per liter or parts per million - or one ounce in 7,350 gallons of water.
ppt	parts per trillion, or nanograms per liter (ng/L)
ppq	parts per quadrillion, or picograms per liter (pg/L)

The following tables contain scientific terms and measures, some of which may require explanation.

Information about Source Water Assessments

The TCEQ completed an assessment of your source water and results indicate that some of your sources are susceptible to certain contaminants. The sampling requirements for your water system are based on this susceptibility and previous sample data. Any detections of these contaminants may be found in this Consumer Confident Report. For more information on source water assessments and protection efforts at our system, contact Tim McClain, 325-248-3596

System Susceptibility Summary										
Asbestos	Cyanide	Metals	Microbial	Minerals	Radiochemical	Synthetic Organic Chemicals	Disinfection Byproduct	Volatile Organic Chemicals	Drinking Water Contaminant Candidate	Other
HIGH	HIGH	HIGH	HIGH	HIGH	HIGH	HIGH	HIGH	HIGH	HIGH	HIGH

For more information about your sources of water, please refer to the Source Water Assessment Viewer available at the following URL: <http://gis3.tceq.state.tx.us/swav/Controller/index.jsp?wtrsrc=>

Further details about sources and source-water assessments are available in Drinking Water Watch at the following URL: <http://dww.tceq.texas.gov/DWW>

Source Water Name	Type of Water	Report Status	Location
1 - CIRCLE RD	GW	<u>Active</u>	<u>Llano County</u>
3 - AIRVIEW	GW	<u>Active</u>	<u>Llano County</u>
4A - AIRVIEW	GW	<u>Active</u>	<u>Llano County</u>
4B - AIRVIEW	GW	<u>Active</u>	<u>Llano County</u>
4C - AIRVIEW	GW	<u>Active</u>	<u>Llano County</u>

NOTE 1: The public is invited to attend the City of Sunrise Beach City Council Meetings held on the Third Thursday of every month during which time matters concerning the City Water Department are discussed and the public has an opportunity to speak about their concerns. The meetings start at 2:30 pm and are held at the Civic Center located at 124 Sunrise Drive, Sunrise Beach, TX 78643.

NOTE 2: In the water loss audit submitted to the Texas Water Development Board for the time period of Jan-Dec 2015, your system lost an estimated 4,226,949 gallons of water (14.29%). If you have any questions about water loss audit, please call 325-248-3596.